

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. TC-12369-2500000056P

Dated: 14/06/25

It is certified that an inspection team headed by Aachana Kumari (Name of Officers with designation) from U.P. Jal Nigam (Rural), Kanpur Nagar, inspected the **Rising Sun Global School, Sachendi, Kanpur Nagar** (Name & Address of the school) on chemist (date of inspection) and on the basis of Water Test Report (Attached) bearing no TC-12369-2500000056P dated 14/06/25 of **Regional Level Water Analysis Laboratory (UP JAL NIGAM)** certified that the **Rising Sun Global School, Sachendi, Kanpur Nagar** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 14/06/27 **from issue date**

Signature with Seal:

Name: Aachana

Designation: Lab in charge


Name & Address of the Office / Department:

To

Rising Sun Global School,

Sachendi, Kanpur Nagar

U.P. JAL NIGAM Kanpur
Nagar.





Analysis Report



District Level Water Analysis Laboratory

Uttar Pradesh Jal Nigam, Rural, 100 H-Block, Gujaini, District Kanpur Nagar,

Pin- 208022



TC no. - 12364

URL No.	TC – 12364-25000000056F	Date	14/06/2025	Page No.	1
Customer Details					
Customer Name and Address	Rising Sun Global School, Sachendi, Kanpur Nagar				
Ref Letter No. & Date	-				
Sampling Method ISO 17614 (Part – 1):2021	Sample Discription – Drinking Water				
Basic Details of Sample					
District	Kanpur Nagar	Block	Sachendi		
Gram Panchayat	Sachendi	Village	Sachendi		
Habitation	-	Location	Rising Sun Global School, Sachendi, Kanpur Nagar		
Water Source	Drinking Water	Sample Code	K/25/06/56P		
Quality of Sample	Normal, Acitic	Date of S.C.	12/06/2025		
Receiving Date	13/06/2025	S. Collector	Pawan Kumar Singh		
Sample Depositor	Pawan Kumar Singh				
Analysis Start Date	14/06/2025	Analysis Completion Date	14/06/2025		
Technical Data of Analysis					
S. No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH @25°C	7.23	6.5-8.5	6.5-8.5	IS 3025 (Part II): 2023 (Electrometric Method)
2	Turbidity (NTU)	1.21	1.00	5.00	IS 3025 (Part 10): 2023 (Nephelometer Method)
3	TDS, mg/l	120.1	500	2000	IS 3025 (Part 16): 2023(Gravimetric Method)
4	Chloride (as Cl), mg/l	10	250	1000	IS 3025 (Part 32): 2023(Titration Method)
5	Total Alkalinity (as Na ₂ CO ₃), mg/l	70	200	600	IS 3025 (Part 23): 2023(Titration Method)
6	Total Hardness (as CaCO ₃), mg/l	60	200	600	IS 3025 (Part 21): 2023 (Titration Method)
7	Calcium (as Ca), mg/l	30	75	200	IS 3025 (Part 40): 2023
8	Magnesium (as Mg), mg/l	-	30	100	IS 3025 (Part 46): 2023
9	Sulphate (as SO ₄), mg/l	12	200	400	APHA 24 th Ed 2023, 4500-SO ₄ (E. Turbidimetric Method)
10	Nitrate (as NO ₃), mg/l	1.0	45	No Relaxation	APHA 24 th Ed 2023, 4500-NO ₃ (B. Ultraviolet Spectrophotometric Screening Method)
11	Fluoride (as F), mg/l	0.023	1.0	1.5	APHA 24 th Ed 2023, 4500-F (C. Ion Selection Electrode Method)
12	Iron (as Fe), mg/l	0.12	1.0	No Relaxation	APHA 24 th Ed 2022, 3500-Fe (B Phenanthroline Method)
13	Colour	5	5HU	15HU	APHA 24 th Ed 2023 Colour Method (Platinum cobalt Visual Comparison):2017
Note 1. This Certificate refers only to the particular sample(s) submitted for testing. 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory. 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements. 4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports unless otherwise specified. 5. Test performed at 25 ± 3°C temperature and 50 ± 15% relative humidity.					
 Prepared by (Vishnu Singh) Lab Technician			 Authorized Signatory (Archanã Kumari) Quality/Technical Manager Contact No. – +91 - 7561920301		

End Of Report